
### Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 1

(As of 11:00 March 24th, 2011)




### Major Events after the earthquake

- 11<sup>th</sup> 14:46: Under operation, Automatic shutdown by the earthquake
- 11<sup>th</sup> 15:42: Report based on the Article 10 (Total loss of A/C power)
- 11<sup>th</sup> 16:36: Occurrence of the Article 15 event (Inability of water injection of the Emergency Core Cooling System )
- 12<sup>th</sup> 1:20 Occurrence of the Article 15 event (Unusual rise of the pressure in PCV)
- 12<sup>th</sup> 10:17 Started to vent
- 12<sup>th</sup> 15:36 Sound of explosion
- 12<sup>th</sup> 20:20 Started to inject seawater and borated water to core
- 23<sup>rd</sup> 02:33 The amount of injected water to the Rector Core was increased utilizing water supply line in addition to the Fire Extinguish line.  $(2m^3/h \rightarrow 18m^3/h)$ 09:00 Switched to water supply line only.(18m<sup>3</sup>/h $\rightarrow$ 11m<sup>3</sup>/h)
- 24<sup>th</sup> 11:30 Lightening in the Central Control Room was recovered.
  - \*1 Residual Heat Removal System
  - \*2 Emergency Diesel Generator \*3 Primary Containment Vessel \*4 Suppression Pool

Current Conditions: Seawater is being injected to the core

Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 2 (As of 11:00 March 24th, 2011) Major Events after the



Current Conditions: Water is being injected to Spent Fuel Pool and seawater is being injected to the core

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

### Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 3

(As of 11:00 March 24th, 2011)



11th 14:46 Under operation,

Automatic shutdown by the earthquake

11<sup>th</sup> 5:42 Report based on the Article 10 (Total loss of A/C power)

12<sup>th</sup> 20:41 Started to vent

13<sup>th</sup> 5:10 Occurrence of the Article 15 event (Inability of water injection of the Emergency Core Cooling System)

13<sup>th</sup> 9:20 Started to vent

13<sup>th</sup> 13:12 Started to inject seawater and borated water to core

14<sup>th</sup> 5:20 Started to vent

14<sup>th</sup> 7:44 Occurrence of the Article 15 event (Unusual rise of the pressure in PCV)

14<sup>th</sup> 11:01 Sound of explosion

16<sup>th</sup> around 8:30 White smoke generated.

17<sup>th</sup> 9:48~10:01 Water discharge by the helicopters of Self-Defense Force (4 times)

19:05 ~ 20:07 Water spray from the ground by High pressure water-cannon trucks (Police: once, Self-Defense Force: 5 times)

18<sup>th</sup> before 14:00 ~ 14:38 Water spray from the ground by 6 fire engines of Self-Defense Force

~14:45 Water spray from the ground by a fire engine of the US Military

 $19^{\rm th}~0:00~01:00$  Water spray by Tokyo Fire Department  $19^{\rm th}~14:10~20^{\rm th}~3:40$  Water spray by Tokyo Fire Department

20<sup>th</sup> 11:00 Pressure of PCV rose(320kPa). Afterward fell.

20<sup>th</sup> 20:39 ~ 21<sup>st</sup> 3:58 Water spray by Tokyo Fire Department


21st about 15:55 Grayish smoke generated and was confirmed to be died down at 17:55.

22<sup>nd</sup> 15:10 ~15:59 Water spray by Tokyo Fire Department 22<sup>nd</sup> 22:43 Lightening in the Central Control Room was recovered.

23<sup>rd</sup> 11:03 ~13:20 Injection of about 35ton of sea water to the Spent Fuel Pool (SFP) via the Cooling and Purification Line (FPC)

23<sup>rd</sup> around 16:20 Black smoke generated and was confirmed to died down at around 23:30 and 24<sup>th</sup> 4:50.


24<sup>th</sup> 5:35 Injection of sea water to SFP via FPC (12:08 Confirmed the injection of 4~5t/h)



\*3 Primary Containment Vessel \*4 Suppression Pool Current Conditions: Water spray to Spent Fuel Pool and sea water injection to the Reactor Core

Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 4

(As of 11:00 March 24th, 2011)



Current Conditions: No fuel is in RPV\*3. Water spray to Spent Fuel Pool

\*3 Reactor Pressure Vessel


(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

\*1 Residual Heat Removal System

\*2 Emergency Diesel Generator

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 5 (As of 11:00 March 24th, 2011)

#### In periodic inspection outage



Reactor Pressure: 0.108MPa\*
Reactor Water Level: 1,925mm

Reactor Water Temperature: 86.8°C Condition: Pressure is under control. \*converted to absolute pressure

Reactor Pressure Vessel Temperature: Monitoring by Reactor Water Temperature

\*Heat removal was carried out alternately with the water in the Reactor Core and in the Spent Fuel Pool.

#### **Current Conditions:**

Cold shutdown at 14:30 March 20th.

Receiving electricity from external power supply from 11:36 March 21st.

Seawater pump for Residual Heat Removal (RHR) was automatically stopped when the power supply was switched from the temporary to the permanent at 17:24 March 23<sup>rd</sup>.

(Editorial committee for Nuclear Energy Handbook, Nuclear Energy Handbook)

# Conditions of Fukushima Dai-ichi Nuclear Power Station Unit 6 (As of 11:00 March 24th, 2011)

