

March 25, 2011

Nuclear and Industrial Safety Agency

Survey result of workers' exposure in the turbine building of Unit 3 of Fukushima Dai-ichi Nuclear Power Station

1. As for the case mentioned in the title occurred yesterday, TEPCO reported the survey result with regard to the work environment as attached.
2. As a cause of this case, TEPCO assumed that the workers kept continuing work even though the individual dosimeters sounded alarm since they didn't notice the change of the work environment of the day from the previous day (23th).
3. For this reason NISA directed TEPCO orally to review the radiation control measures immediately and improve it from the point of recurrence prevention.